

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
<b>MRI "The ROC" Radiology Outpatient Center</b>							
47000	FAN-EXHAUST	Exhaust Fan	under roc/crawlspace				1 VOLTS: 460 PHASE:3 AMPS: 4.5 H.P.: 1/12 R.P.M: 1740 O.E.M.: M13154T145T BELTS: A-51
51974	AHU, 190D011612568-02 #5	AIR HANDLER UNIT BARD	ROC	BARD	1900011612568-02	1	
51975	AHU, 190D011612569-02 #6	AIR HANDLER UNIT BARD	ROC	BARD	1900011612569-02	1	
51976	AHU, 190D011612567-02 #7	AIR HANDLER BARD	ROC	BARD	1900011612567-02	1	
51977	AHU, 190011612570-02 #8	AIR HANDLER BARD	ROC	BARD	190F011612570-02	1	
51978	AHU, 190H011640097-02 #4	AIR HANDLER BARD	ROC	BARD	190H011640097-02	1	
51979	AHU, 1900011612571-02 #2	AIR HANDLER BARD	ROC	BARD	1900011612571-02	1	
51981	AC, 31016-53010 ROOF TOP #4	AIR CONDITIONING UNIT		CARRIER	31016-53010	1	
51982	AC, 3101G 23766 ROOF TOP #2	AIR CONDITIONING UNIT	ROC	CARRIER	3101G 23766	1	
51991	FRIG			KENMORE	010301082	1	1 HZ: 60 PHASE: SINGLE VOLTS: 115 FULL AMPS: 6.5 R-134A 4 OUNCES TYPE: C22TFA96
51997	ICE-MCH	ICE MACHINE SCOTSMAN		SCOTSMAN	405 328 11R	1	
57891	AHU, 190F011628812-02 #1	AHU (CLOSE TO MAIN DOOR )	ROC	BARD	190F011628812-02	1	
57892	AC, 3301G 23059 ROOF TOP #3	AIR CONDITIONING UNIT	ROC	CARRIER	3301G 23059	1	
57893	AC, 3501G 21002 ROOF TOP #1	AIR CONDITIONING UNIT	ROC	CARRIER	3501G 21002	1	
57895	AHU, 190D011612566-02 #3	AHU	ROC	BARD	190D011612566-02	1	
					<b>Subtotal</b>	<b>15</b>	

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
<b>Fannin Bank Building</b>							
39000	UNIT-CD-AIR, 8 TON	Air Condenser	FBB Roof / 17th flr	CARRIER			1 Volts: 208/230, Phase: 3, HZ:60, Volts minimum and masimum 187/254, Motor: 06d225, Reciprocating Compressor
39001	AHU	Air Handler Unit	FBB3.300	FRIEDRICH	JULT01400		1 Volts, 230/208, 60 hz, single phase, indoor motor load, 03/03 amps, disconnect switch 15amps, Split Type Air Conditioner Unit
39002	AHU	Air Handler Unit	FBB11.140	CARRIER	1299F06845		1 Volts:208-230/460, 3ph, 60hz, 5.8/2.6 fla, 2.4hpm .79 kw, 7.3/3.3 amps, belt A-39, Filters 4@16"x24"x2" box pleted
39003	AC-PKG-UNIT, EXTERIOR	Exterior Package Unit	FBB2.230.ROOFT OP	CARRIER	2296H30996		1 Volt: 460, 3ph, 60hz, 55 LRA, R-22 Refrigerant, 5.8 LBS Charge, 2.6 kg, hi-439 psi, low 158 psi, 0.8-3.2 FLA
39004	UNIT-CD-AIR	Air Condenser	FBB3.ROOF	FRIEDRICH	LKAH00121		1 Volts: 192, One Compressor: Compressor, R-22 50 Ounces refrigerant, HZ: 60, Amps: 8.6/7.8, RLA 7.20, Compressor LRA 49.0, Outdoor Fan Motor: MR18C3d, Indoor Fan Motor: 18C3d, Fan motor indoor: F.L.A.: .30, Outdoor Fan Motor: L.R.A.: .80, H.P 1/8, MINIMUM Amps:12.0, Breaker Amps:20
						<b>Subtotal</b>	<b>5</b>
<b>Fannin Holcombe Building</b>							

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
66005	AHU-1-1	Air Handler Unit	FHBB.0010	CARRIER			1 Belts: 2 ea., B-85", Filters: 12 ea, 19 1/2" x 19 1/2" x 2", Amps:22 Motor: Newman; Supplier: Newman Electric Co., Induction Motor: Frame:254U/dd2152bb, volts: 208/220/440, Serial:#1142802, Newark, New Jersey, HP 7.5 RPM 1750.
66006	AHU-B-3 (CHEDRICK IBM)	Air Handler Unit	FHBB.0010	CARRIER			1 Belts: 2 ea., box 93", filters: 18 ea., 19 1/2"x 19 1/2"x 2", Motor: G.E., Model#:5K4254A21, Serial OX 73608, Frame: Type 254U, H.P.:7.5, Volts: 208-220/440, Phase:3. HZ:60
66029	CHR-#2	Chiller	FHBB.0010	CARRIER	770725919	1	Comp:Serial#102296, Motor:volts-460, Amps-624, RPM-3504, ph-3, Control Panel-Model-19EA41, volt-115, Amp-5, Storage tank#302229, unishell#202222, Small Comp-Model#06DA1070GA0600, Serial#A704516, Filter driers:Qty-2, #C-967-G
66030	CHR-#1	Chiller	FHBB.0010	CARRIER	770625920	1	Comp: Model#19EA42350, Part#102295, 550 tons, R-12, Motor: Volts-460, Amp-624, RPM-3504, ph-3, Control Panel: model-19EA41, Volt-115, Amp-5, Main comp-part#102295, Unishell-Part#202221, Storage Tnk-Part#302227

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
66031	PUMP-CDW, CWP #2	Condenser Water Pump	FHBB.0010	AURORA		1	Pump:Type-411BF, Size:6"x15", GPM-1500, FTHD-99, Motor: Volt-460, Amps-70, Hp-60, RPM-1765, ph-3, Frame-364TS, part#6321177-05
66032	PUMP-CHW-RTN, CHWP #2	Chilled Water Return Pump	FHBB.0010	AURORA		1	Motor: Part#6-313482-02, Volts-460, Amps-40, HP-60, RPM-1765, Frame 3241
66041	AHU-B-2	Air Handler Unit	FHBB.0010	CARRIER		1	Motor:G.E. Induction Motor, Model#:5K184AG211, HP:2, Phase:3, Volts:208/220/440, Frame:Type:k, Serial#:NA, Belts: One b-64, Filters: 2 ea., 15.5x24.5x
66046	PUMP-CHW, CHWP #1	Chilled Water Pump	FHBB.0010	AURORA PUMP		1	U.S. Electrical motor: model #R357, cat#D40P2B, HP40, RPM1780, Volt 230/460, Amp 91/46, 3 pH, Frame-324T, Motor Bearings: S.E.6311-22-J/C3, Opp.E.-6211-22-J/C3, ID#-E1001066585-003R-05, Cat#D40P2B
66047	PUMP-CDW-CWP-1	Condenser Water Pump	FHBB.0010	AURORA PUMP	411-BF	1	
66050	PUMP-DWTR, DCWP #1	Domestic Cold Water Pump	FHBB.0010	AURORA PUMP		1	Pump;type-421BF, GPM-235, size-2 1/2 x 12A, Ft. HD-216, RPM-1750, Century Motor: part#6-312792-06, hp-25, RPM-1750, volt-230/460, amp-63/31.5, phase-3, frame-284T, motor bearings:SE-311, Opp.E.-210

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
66051	AHU-1-2	Air Handler Unit	FHBB.0010	CARRIER	63260640 VL	1	Belts:2 ea. B-75, Filters: 6 ea., 15 1/2 x 19 1/2 x 2. Motor: Weg., Mfgd., Rochester, New York, Induction motor, Phase 3, Model: 8L-3-18-1821, HP3, RPM 1750, Volts:208-230/460, Amps:8.6 and 4.3 Frame: 182T
66067	PUMP-SUMP-STRM-S.P.#2	SUMP PUMP MOTOR	FHBB.0016	WEINMAN	140189-2	1	GPM-200, Ft. Hd-32, RPM 1750, motor: model#1E213TFR44BBW, Type:TFR-BPE, HP3, volt 230/460, amps 8.4/4.2, 1740 RPM, 3 phase, pump has float switch, but can't read tag, tag is faded and painted over.
66068	PUMP-SUMP-STRM WTR MTR #1	SUMP PUMP STORM WATER SEWER MOTOR	FHBB.0016	MARATHON ELECTRIC	113871	1	
66069	PUMP-SUMP-STRM WTR #1	SUMP PUMP SEWER	FHBB.0016	WEINMAN	140190-2	1	
66070	AHU-1-3	AHU	FHBB.0017	CARRIER		1	Belts: two ea., B-83, Filters:9 ea., Motor: Baldor, Cat#:N3306, Spec 37M47Z42, Series:1.15 Code:H, Bearings:de6307, Serial#:FO108123165, belts, HP:5, Volts:230/460, Amps:13.6/6.8, RPM:1725, Frame:215, Volts:208@15.2 amns HZ60 Phase:3
66071	AHU-B-1	AHU	FHBB.0017	CARRIER		1	Air Handler has a Dayton Motor 3 HP RPM 1740/1440, 3 phase volts, 208/220-440 amps 9.0/4.4 Frame JS213, Belt Size 1 ea B77-Filtersize, 9 ea. 20x20
66078	AHU-1-4	Air Handler Unit	FHB1.0005	CARRIER	63222390	1	volt-120/277, 40 amp, timing motor, 120 volt
66082	FCU-#5	Fan Coil Unit	FHB1.S104A	YORK	EHCS275587	1	

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
66082	FCU-#5	Fan Coil Unit		YORK	EHCS275587	1	Volts: 460, Motor: 3/4 hp, 3.0 amps, Filters: 16x25x1, qty-2
66083	PUMP-HSE, #1	House Water Pump, #1	FHBB.0010	WEINMAN		1	Super E Motor: Cat#EM3314T, spec#37F614x895, HP-15DP, RPM-3525, volt-230/460, amps-34/17, 3ph, frame-215T, motor bearings: font-6206, rear 6307
66084	FAN-EXH, #3-RSTRM	Exhaust fan #3 for basement restrooms.	FHB1.121			1	HP:one, volts:220/440, Amps:3.4/1.7, RPM:1730, Phase:3, rame:182, belts:one belt only, size:4L480
66084	FAN-EXH, #3-RSTRM	Exhaust fan #3 for basement restrooms.				1	
66088	FCU-#6	Fan Coil Unit	FHBM.S118	MAGIC AIRE	940283813	1	
66088	FCU-#6	Fan Coil Unit	FHBMS.118	MAGIC AIRE	940283813	1	
66089	FCU, #1	Fan Coil Unit	FHB2.203	TRANE	G15173682	1	
66090	FCU, #3	Fan Coil Unit	FHB2.203	TRANE	G23175184	1	
66090	FCU, #3	Fan Coil Unit	FHB2.225A	TRANE	G23175184	1	Motor:volts-460, amps-1.4, phase 3, hp 3/4, filter: 20x20x1, qty-2, belt: A44, qty 1
66091	FCU, #3	Fan Coil Unit	FHB2.225A	TRANE	G24175441	1	
66146	PUMP-SUMP-STRM WTR-B	SUMP PUMP	FHB.GARAGE BSMNT B-4	GOULD	H0339067	1	Volt 460, RPM 1725, amp 6.0, phase 3.
66147	PUMP-SUMP-STRM WTR-A	SUMP PUMP	FHB.GARAGE BSMNT B-4	GOULD	H0339066	1	Volt 460, RPM 1725, amp 6.0, phase 3.
66155	TANK-WTR-DOM-STRG-ALRM	DOMESTIC WATER STORAGE TANK ALARM	FHBB.0010		LL39420	1	
66155	TANK-WTR-DOM-STRG-ALRM	DOMESTIC WATER STORAGE TANK ALARM			LL39420	1	Amps:10, Volts:120, Four Relays:15723T2P2, Five Relays:874704- KRPA11AG120 Three transformers Type 1d1d0, 150 volts, secondary 300 volts

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
66167	PUMP-SUMP,STRM WTR MTR CTRL	Sump Pump Motor Control Box -A- pump 1-2	FHBB.0016	FURNAS CO.	79044	1	This box has 2 breakers: Westinghouse Cat:EH3015-15 amp 3 pole, 600 volts also has 2 starters size 0, Furnas, 3 phase, 600 volts, CAT14GST32A, 18 amp max-120-240 volt coil, also has alternator Model HR-2, class 7100, Type 71010-5 amp, also got 2 transformers, type MC 480 volt, 120v-600 25 VA
66168	PUMP-SUMP-CTRL BOX A 1,2	Sump Pump Control Box -A- pump 1-2	FHBB.0016	FURNAS CO.	79044	1	This box has 2 breakers, Westinghouse CATEH3015, 15 amp, 3 pole, 600 volt, also has 2 starters, size 0, Furnas 3 phase 600 volts, CAT#14CS+32A-18 amp max 120/240 coil also has a alternator model-HR-2 Class 7100 Type 71010, 5 amp, also got 2 transformers type mc 480 volts, 120 volts, 60cy 25 va.
66174	JOCK-PUMP-CTRLR	JOCKEY PUMP CONTROLLER	FHBB.0016		AK-9312102-01	1	Unit has 3 FRS-R-4 fuse 600volt, contractor, 3 pole 600v, coil, 600v, 60 hz, T6, 2F(335500129, pressure switch, type DA-31-2-9-5serial T39E-14849-6A, spec 1325, Cat:167374-00 Mercoïd
66178	PUMP-STRM, #2	STORM SUMP PUMP	FHBB.0016			1	Motor: Model#-1E213TFR44BBw, Type#TFR-BPE, hp3, volt, 230/460, amps 8.4/4.2, RPM 1740, phase 3, float switch, class#9036, type#DW1, Form#2604B2G1-1641, volt 230

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
66179	PUMP-SUMP-SWR, #2	SEWER SUMP PUMP	FHBB.0016	WEINMAN			1 Pump:GPM-200, Ft. HD-32, Rpm-1750, Motor: Model#LE213TFR44BBW, Type # TFR BPE, Hp-3, Volt 230/460, Amp 8.4/4.2, RPM-1740, phase 3, Float switch: Class#9036, Type#DW1, Form#2604B2G1-1641, volt 230
66195	AHU, MEZ	AIR HANDLER UNIT	FHBM.123	TRANE	KOOL73069A	1	Motor:volt-460, amp-13.4, RPM-1745, hp-10, ph-3, frame-S215T, belts: BX59, qty-2, filter:20x20x2, qty-4, 16x20x2, qty-4
66196	VFD-BOX	VARIABLE FREQUENCY DRIVE BOX	FHBM.123	MAGNETEK	272832	1	3 phase-480 volt, 16 amp, type GPD506, BP unit has a breaker, 30 amp, 3pole, CAT#GJL36030, MO4, Magnetek Phone#IBW-541-0939
66242	FCU-#10	FAN COIL UNIT	FHB.ELEV PENTHSE	YORK	NHCS021132 + 33	1	
66243	UNIT-AIR-CNDTN-CD, ACCU-9	AIR CONDITIONER CONDENSER UNIT	FHB ROOFTOP		6417F210227988	1	
66245	VFD-#1	VARIABLE FREQUENCY DRIVE FOR CT-3	FHB12.0001	TOSHIBA	990409660	1	
66251	FAN-EXH, #1 RSTRM	EXHAUST FAN				1	
66257	UNIT-AIR-CNDTN-CD, #5	AIR CONDITIONING CONDENSER UNIT	ROOFTOP	LIEBERT	D22675	1	
66259	UNIT-AIR-CNDTN-CD, #11	AIR CONDITIONING CONDENSER UNIT	ROOFTOP	CARRIER	3399G00182	1	
66260	UNIT-AIR-CNDTN-CD, #10	AIR CONDITIONING CONDENSER UNIT	ROOFTOP	RUUD	G417F050213374	1	
66262	VFD-#2	VARIABLE FREQUENCY DRIVE	FHB12.0001	TOSHIBA	990402434	1	
66263	FAN-EXH, COMP RM	EXHAUST FAN	FHB12.0001	DAYTON		1	
66266	DRYR-AIR	AIR REFRIGERATION DRYER	FHB11.0009	SPEEDAIRE	G035A115010750 6	1	
66267	COMP-AIR	Air Compressor for back up AUX	FHB11.0009	QUINCY	20031105-0041	1	
66270	COMP-AIR	Air Compressor	FHB11.0009	CURTIS	A3090559	1	
66292	PUMP-DWTR-BSTR-SYS	Duplex Domestic Water Booster System	FHBB.0016	NAMCO		1	
66300	PUMP-DWTR-BSTR, #1	Domestic Water Pump	FHB11.0009	TACO		1	

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
66301	PUMP-DWTR-BSTR, #2	Domestic Water Pump	FHB11.0009	TACO		1	
66304	PUMP-HOT-WTR-CIR	Hot Water Circulating Pump	FHB11.0009	ARMSTRONG		1	
66308	PUMP-WTR, ZONE S2P #4	Zone Water Pump South	FHB11.0010	TACO		1	
66309	MTR-AHU-INT-2	Motor for Main Air Handler	FHB11.0010	TOSHIBA	030403577	1	
66310	MTR-AHU-EXT-1	Motor for Air Handling Unit	FHB11.0010	MAGNETEK		1	
66311	PUMP-FIRE-BSTR	Booster Pump for Fire Pump	FHB11.0009	PEERLESS	4817	1	
66312	CLG-TWR-CT2-CELL#2	COOLING TOWER FOR CT2-CELL#2	FHB.ROOFTOP	MARLEY	152471-002NC5231SM-99	1	
66313	CLG-TWR-CT2 CELL #1	COOLING TOWER	FHB.ROOFTOP	MARLEY	152471-003NC5231SM-99	1	
66314	CLG-TWR-CT-3 CELL#3	COOLING TOWER	FHB.ROOFTOP	MARLEY	152471-002NC5231SM-99	1	
66320	PUMP-HOT-WTR, ZONE #5 HEX5	Hot Water Pump	FHB11.1120F	BELL & GOSSETT	2283054	1	
66321	PUMP-HOT-WTR-CIR	Hot Water Circulating Pump Return				1	
66322	VFD	Variable Frequency Drive	FHB11.0010	DAN FOSS GRAHAM	116400Y243	1	
66323	PUMP-BLR-FEED-#1	Boiler Feed Pump	FHB11.1120F	AURORA	02-523911	1	
66324	PUMP-BLR-FEED-#2	Boiler Feed Pump	FHB11.1120F	AURORA	02438314	1	
66326	UNIT-AIR-CNDTN-CD-ACCU #2- KATR	Air Conditioning Unit for Katrina's North Unit	FHBG.PARKING RAMP	COLEMAN EVCON	960677885	1	
66329	UNIT-AIR-CNDTN-CD-ACCU #1	AIR CONDITIONER UNIT	FHBG.PARKING RAMP	YORK	EGCM351401	1	
66335	UNIT-AIR-CNDTN-CD-ACCU-1	Air Condition Condenser Unit	FHB.FRONT LOW ROOF	TRANE		1	
66337	UNIT-AIR-CNDTN-CD-ACCU-2	Air Condition Condenser Unit	FHB.FRONT LOW ROOF	TRANE	30646RG2F	1	
66341	AC, TRANE-A4006A	Air Conditioner Unit	FHB.ROOF FR	TRANE	G19198174	1	
66347	FAN-EXH, #2 PRNT SHOP	Exhaust Fan Print Shop	FHBB.0030E	BALDOR	F194	1	
66348	AC-PKG-UNIT	AIR CONDITIONER UNIT	FHBB.0050		NKMN248504	1	
66349	FCU, #2	FAN COIL UNIT, Katrina's Lunch Room	FHBB.0050	COLEMAN EVCON	961137489	1	
66350	FAN-EXH-PUMP-SUMP	Exhaust Fan Basement Pump Room	FHBB.0016B	GENERAL ELECTRIC	YLL261405	1	
66380	PUMP-CHW, CHWP #1	Chilled Water Pump	FHBB.0010			1	
66381	PUMP-CDW, CWP #1	Condenser Water Pump	FHBB.0010		411-BF	1	
66385	PUMP-DWTR, DCWP #1	Domestic Cold Water Pump	FHBB.0010			1	
66395	PUMP-DWTR, DHWP #2	Domestic Hot Water Pump	FHBB.0010			1	

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
66396	PUMP-DWTR, DHWP #1	Domestic Hot Water Pump	FHBB.0010		730-B-77-00131	1	
66398	PUMP-HOT-DWTR	Domestic Hot Water Pump	FHBB.0010			1	
66399	PUMP-HSE-WTR, #1	House Water Pump	FHBB.0010	WEINMAN		1	
66431	PUMP-CTRL, BOX A 1-2	Pump Control	FHBB.0012		79044	1	
66432	PUMP-CTRL, BOX B 1-2	Pump Control Box	FHBB.0016		79044	1	
66443	PUMP-SUMP-STRM, #1	Storm Sump Pump	FHBB.0016	WEINMAN		1	
66446	PUMP-SUMP-SWR, #1	Sewer Sump Pump	FHBB.0016	WEINMAN	140190-2	1	
66452	AHU	Air Handler Unit	FHBB.0020C	CARRIER	2285G39518	1	
66456	COMP-AIR	Air Compressor	FHBB.00300	CHALLENG	A3090559	1	
66460	VFD-#3	VARIABLE FREQUENCY DRIVE	FHB12.0001	TOSHIBA	990709527	1	
66475	PUMP-JOCK-FIRE	FIRE JOCKEY PUMP	FHB11.0009	FRANKLIN ELECTRIC	L93	1	
66476	PUMP-BSTR-FIRE	FIRE BOOSTER PUMP	FHB11.0009	UNI	3512031	1	
					<b>Subtotal</b>	<b>92</b>	
<b>St. Agnes Warehouse</b>							
17599	AHU	AIR HANDLING UNIT	WSA.000	JANITROL	MMW5612838	1	
40190	AHU	AIR HANDLER UNIT	WSA1.001			1	
54001	DXAC	DX AIR CONDITIONING UNIT	WSA.Warehouse	AMERICAN STANDARD	3124L85F	1	VOLTS: 200/230 PHASE: ONE HZ: 60 MINIMUM AMPS: 17 MINIMUM FUSE: 30 AMPS MAXIMUM BREAKER: 30 AMPS R-22, 4 LB CHARGE COMPRESSOR: 13.2 RLA, LRA 71 OUTDOOR FAN MOTOR: .90 FLA 1/8 H.P SAFETY SWITCH ITE CATALOG # NFR 322 ENCLOSURE TYPE 3R, INDOOR OR OUTDOOR 60 AMPS 240 VOLTS 3 PHASE 15 LB NON FUSE
54002	FAN-EXH	EXHAUST FAN	WSA.Warehouse	BROAN		1	120 VOLTS 60 HZ 75 AMPS 50 CFM 3.0
					<b>Subtotal</b>	<b>4</b>	
<b>Grand Street Warehouse/Dupree</b>							
50045	AC	AIR CONDITIONING UNIT	WGS.Roof		MO45JKU2H	1	

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
54100	FAN-EXH, ROOF	EXHAUST FAN	WGS.Roof	AIR MOVEMENT & CONTROL			1 BELTS: NONE FAN ATTACHED TO MOTOR SHAFT MOTOR: DAYTON MODEL#: 4M222 HP: 1/11 RPM 1500 VOLTS: 115 AMPS: 3.4 HZ: 60 PHASE: SINGLE
						<b>Subtotal</b>	<b>2</b>
<b>Corder Street Warehouse</b>							
49000	AC, WINDOW	Air Conditioning Unit-window	WCC. Bay 13	CARRIER	1694B64986		1 A/C COOL 115 VOLTS 1 PHASE 60 HZ BTU 10200 9 AMPS 1020 WATTS HEAT 5200BTUS 16.1 AMPS 1840 WATTS
						<b>Subtotal</b>	<b>1</b>
<b>Landscape Warehouse Building</b>							
40202	COMP-AIR, SPEEDAIRE	AIR COMPRESSOR	LWB				1
46000	FAN-EXH, REAR WHSE	Exhaust Fan	LWB.Rear Warehouse	MARATHON ELECTRIC	MT39107008230		1 VOLTS: 115/230, 60HZ, SINGLE PHASE, 1/10HP, 9/0.45AMPS, 1725RPM, TYPE:U185BQ - THERMALLY PROTECTED
46001	FAN-EXH	Exhaust Fan	LWB.GREENHOU SE	LOREN COOK CO			1 BELT: ONLY ONE, A, 4L470, BELT MOTOR: CAT#B307, 60HZ, HP-1/2, RPM:1725, 115VOLTS, 7.2FLA

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
46002	COMP-AIR	Air Compressor	LWB.GREENHOU SE	SPEEDAIRE		1	MAXIMUM CIRCUIT FUSE AMPS: 60, MIN. GAUGE WIRE: 6, WIRE TYPE: IW, HEATING ELEMENT: 5H604654610, LIMIT CONTROL: 5H604668A1, CONTACTOR: 5H604385D41, SAFETY SWITCH: 60AMP, 240VOLT, 15HP, NP 266211-B, SINGLE PHASE, NONE FUSE BTU CAPACITY: 34130, MOTOR: 9F10238A, 230VOLTS, 6HZ, SINGLE PHASE, 1.28AMPS, 240 LINE VOLTS, 42.9LINE AMPS, 54 MIN. AMPACITY
<b>Subtotal</b>						<b>4</b>	
<b>Faculty Center Bridge</b>							
37000	AHU, BRDG N	Air Handler Unit	FC.Bridge N	CARRIER	3784T23904	1	CENTURY MOTOR#6- 330772-0Z, FRAME: S215T, 3 PHASE, TYPE: SC, 10HP, 1750RPM, VOLTS: 230/460, 40AMPS HAS 2 BELTS SIZE BX50, FILTERS SIZE: 1,1- 25X100 COBRA LINK, 1- 16X100 COBRA LINK SAFETY SWITCH: WESTINGHOUSE CAT#HUN361, 30AMP, 3PHASE, 600VOLTS, NON FUSE-MOTOR PUMP: ARMSTRONG MODEL#AVC- 56T17D1030BP, 1/2HP, 60HZ, VOLTS 208/230/460, 3 PHASE, TYPE T5 & 2EA STAEFA CONTROL SYSTEM TYPE M3R500C

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
37001	AHU, BRDG S	Air Handler Unit	FC.Bridge S	CARRIER	3784T23903	1	FILTER SIZE: 1-25X100 COBRA, 1-16X100 COBRA, BELT: 2EA, BX-50, MOTOR IS A CENTURY CAT#301, SERIALCODE:BX01 TYPE SCE, FRAME-S215T, MODEL#SOP7501, 480VOLT, 3 PHASE, AMP 26.6-13.3, DE BEARING #307, ODE BEARING #206 UNIT HAS A PUMP MOTOR MODEL#5VM56T17D1030A-P, 1/2HP, 3PHASE, 1725RPM - SAFERY SWITCH THAT CONTROLS IT: WESTINGHOUSE CAT#HUN361, 480VOLTS, NONE FUSE - HAS 2 STAEFA CONTROL SYSTEMS, TYPE M3R500G
37013	PUMP-SUMP, DSCNT SP-16	DISCONNECT SUMP PUMP	FC.Pit	CUTLER HAMMER		1	30AMP, 600VOLT, 3 PHASE, SWITCH CONTROLS THE SUMP PUMP (PUMP HAS NO TAG)UNIT HAS A PUMP MOTOR MODEL#5VM56T17D1030A-P, 1/2HP, 3PHASE, 1725RPM - SAFERY SWITCH THAT CONTROLS IT: WESTINGHOUSE CAT#HUN361, 480VOLTS, NONE FUSE - HAS 2 STAEFA CONTROL SYSTEMS, TYPE M3R500G
						<b>Subtotal</b>	<b>3</b>
<b>Faculty Center</b>							
40000	PUMP-COND, CRU1	CONDENSATE RETURN PUMP	FC1.1032	MARATHON ELECTRIC	103381	1	PUMP G9 1750 RPM

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
40001	FAN-PRESS-STRWL, #2	STAIRWELL PRESSURE FAN #2	FC1.1032	PENN VENTILATOR	49K00075	1	STATIC PRESSURE SWITCH 1/2 MAX PRESS 120 VOLTS DDDC FOR PRESSURE FAN TYPE ACH401601632 3 PHASE 480 VOLTS
40002	FAN-PRESS-STRWL, #1	STAIRWELL PRESSURE FAN #1	FC1.3014	PENN VENTILATOR	49K0074	1	STATIC PRESSURE SWITCH 1/2 MAX PRESS 120 VOLTS DDDC FOR PRESSURE FAN TYPE ACH401601632 3 PHASE 480 VOLTS MOTOR 20HP 480 VOLTS 3 PH 23.5 AMPS
40003	FAN-PRESS-STRWL #4, E F-SP- 4	STAIRWELL PRESSURE FAN #4	FC14.1000	BARRY BLOWER	49M0049	1	
40009	PUMP-DWTR-CRCTLNG, DHWCP-1	DOMESTIC HOT WATER CIRCULATION PUMP	FC1.1028	TACO		1	MOTOR 1/40 HP 3250 RPM, 60HZ 120 VOLTS SINGLE PHASE
40010	PUMP-DWTR-CRCTLNG, DHWCP-2	DOMESTIC HOT WATER CIRCULATION PUMP	FC5.1026	TACO		1	MOTOR 1/40 HP 3250 RPM, 60HZ 120 VOLTS 0.52 AMPS SINGLE PHASE
40011	PUMP-DWTR-CRCTLNG, DHWCP-3	DOMESTIC HOT WATER CIRCULATION PUMP	FC9.1026	TACO	006B4	1	MOTOR 1/40 HP 3250 RPM, 60HZ 120 VOLTS 0.52 AMPS SINGLE PHASE
40012	PUMP-DWTR-CRCTLNG	DOMESTIC HOT WATER CIRCULATION PUMP	FC12.1026	TACO		1	MOTOR - 1/40HP, 3250RPM, 60HZ, 120VOLTS, 0.52AMPS, SINGLE PHASE
40056	FAN-EXH, RSTRM F-TE-1	RESTROOM EXHAUST FAN	FC14.1000	CENTRI MASTER	YXC929601	1	BALDOR MOTORS - 5HP, 480VOLTS, 6.5AMPS, 1750RPM, 3PHASE, 60HZ, ODPEE, 184T FRAME, CAT#EM3615T BELT - A69, QTY: 2
40059	COMP-AIR-CTRL, CAC-1	CONTROL AIR COMPRESSOR- FOR STEAM HEAT EXCHANGER CONTROLER	FC1.1032	QUINCY	51247295	1	BALDOR MOTOR 5HP 143 T FR4AME 230/460 VOLT 3.2/ 1.6 AMP 3 PHASE BELT AX 51 COMP FILTER 112835-004

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
40061	DXAC, LIEBERT	LIEBERT DX CONDENSER/COMPRESSOR UNIT	FC9.1028	LIEBERT	0101N39986	1	
40063	AHU	AIR HANDLER UNIT	FC1.1028	TEMPROL	76223	1	BALDO MOTOR 15 HP 1750 RPM 460 VOLT 25.0 AMP 3 PHASE 2.54T FRAME BELTS BX72Q354 DAYCO X 2 FILTER 24X24X2 PLEAT X 8
40064	AHU, 1B	AIR HANDLER UNIT	FC1.1058	TEMPROL	76231	1	BALDO MOTOR 15 HP 1750 RPM 460 VOLT 25.0 AMP 3 PHASE 2.54T FRAME BELTS BX72Q354 DAYCO X 2 FILTER 24X24X2 PLEAT X 8
40065	AHU, 2A	AIR HANDLER UNIT	FC2.1028	TEMPROL	76229	1	BALDO MOTOR 15 HP 1750 RPM 460 VOLT 25.0 AMP 3 PHASE 2.54T FRAME BELTS BX72Q354 DAYCO X 2 FILTER 24X24X2 PLEAT X 9
40066	AHU, 2B	AIR HANDLER UNIT	FC2.1058	TEMPROL	76227	1	BALDO MOTOR 15 HP 1750 RPM 460 VOLT 25.0 AMP 3 PHASE 2.54T FRAME BELTS BX72Q354 DAYCO X 2 FILTER 24X24X2 PLEAT X 10
40067	AHU, 3A	AIR HANDLER UNIT	FC3.1028	TEMPROL	73225	1	BALDO MOTOR 15 HP 1750 RPM 460 VOLT 25.0 AMP 3 PHASE 2.54T FRAME BELTS BX72Q354 DAYCO X 2 FILTER 24X24X2 PLEAT X 11
40068	AHU	AIR HANDLER UNIT	FC3.1058	TEMPROL	76231	1	BALDO MOTOR 15 HP 1750 RPM 460 VOLT 25.0 AMP 3 PHASE 2.54T FRAME BELTS BX72Q354 DAYCO X 2 FILTER 24X24X2 PLEAT X 12
							PLEAT X 13

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
40069	AHU, 4A	AIR HANDLER UNIT	FC4.1028	TEMPTROL	76221	1	BALDO MOTOR 15 HP 1750 RPM 460 VOLT 25.0 AMP 3 PHASE 2.54T FRAME BELTS BX72Q354 DAYCO X 2 FILTER 24X24X2 PLEAT X 14
40070	AHU, 4B	AIR HANDLER UNIT	FC4.1058	TEMPTROL	76219	1	BALDO MOTOR 15 HP 1750 RPM 460 VOLT 25.0 AMP 3 PHASE 2.54T FRAME BELTS BX72Q354 DAYCO X 2 FILTER 24X24X2 PLEAT X 15
40071	AHU, 5A	AIR HANDLER UNIT	FC5.1028	TEMPTROL	76217	1	BALDO MOTOR 15 HP 1750 RPM 460 VOLT 25.0 AMP 3 PHASE 2.54T FRAME BELTS BX72Q354 DAYCO X 2 FILTER 24X24X2 PLEAT X 16
40072	AHU, 5B	AIR HANDLER UNIT	FC5.1058	TEMPTROL	76215	1	BALDO MOTOR 15 HP 1750 RPM 460 VOLT 25.0 AMP 3 PHASE 2.54T FRAME BELTS BX72Q354 DAYCO X 2 FILTER 24X24X2 PLEAT X 17
40073	AHU, 6A	AIR HANDLER UNIT	FC6.1028	TEMPTROL	76213	1	BALDO MOTOR 15 HP 1750 RPM 460 VOLT 25.0 AMP 3 PHASE 2.54T FRAME BELTS BX72Q354 DAYCO X 2 FILTER 24X24X2 PLEAT X 18
40074	AHU, 6B	AIR HANDLER UNIT	FC6.1058	TEMPTROL	76211	1	BALDO MOTOR 15 HP 1750 RPM 460 VOLT 25.0 AMP 3 PHASE 2.54T FRAME BELTS BX72Q354 DAYCO X 2 FILTER 24X24X2 PLEAT X 19
40075	AHU, 7A	AIR HANDLER UNIT	FC7.1028	TEMPTROL	76209	1	BALDO MOTOR 15 HP 1750 RPM 460 VOLT 25.0 AMP 3 PHASE 2.54T FRAME BELTS BX72Q354 DAYCO X 2 FILTER 24X24X2 PLEAT X 20

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
40076	AHU, 7B	AIR HANDLER UNIT	FC7.1058	TEMPROL	76232	1	BALDO MOTOR 15 HP 1750 RPM 460 VOLT 25.0 AMP 3 PHASE 2.54T FRAME BELTS BX72Q354 DAYCO X 2 FILTER 24X24X2 PLEAT X 21
40077	AHU, 8A	AIR HANDLER UNIT	FC8.1028	TEMPROL	76230	1	BALDO MOTOR 15 HP 1750 RPM 460 VOLT 25.0 AMP 3 PHASE 2.54T FRAME BELTS BX72Q354 DAYCO X 2 FILTER 24X24X2 PLEAT X 22
40078	AHU, 8B	AIR HANDLER UNIT	FC8.1058	TEMPROL	73228	1	BALDO MOTOR 15 HP 1750 RPM 460 VOLT 25.0 AMP 3 PHASE 2.54T FRAME BELTS BX72Q354 DAYCO X 2 FILTER 24X24X2 PLEAT X 23
40079	AHU, 9A	AIR HANDLER UNIT	FC9.1028	TEMPROL	76226	1	BALDO MOTOR 15 HP 1750 RPM 460 VOLT 25.0 AMP 3 PHASE 2.54T FRAME BELTS BX72Q354 DAYCO X 2 FILTER 24X24X2 PLEAT X 24
40080	AHU, 9B	AIR HANDLER UNIT	FC9.1058	TEMPROL	76224	1	BALDO MOTOR 15 HP 1750 RPM 460 VOLT 25.0 AMP 3 PHASE 2.54T FRAME BELTS BX72Q354 DAYCO X 2 FILTER 24X24X2 PLEAT X 25
40081	AHU, 10A	AIR HANDLER UNIT	FC10.1028	TEMPROL	76222	1	BALDO MOTOR 15 HP 1750 RPM 460 VOLT 25.0 AMP 3 PHASE 2.54T FRAME BELTS BX72Q354 DAYCO X 2 FILTER 24X24X2 PLEAT X 8
40082	AHU, 10B	AIR HANDLER UNIT	FC10.1058	TEMPROL	76220	1	BALDO MOTOR 15 HP 1750 RPM 460 VOLT 25.0 AMP 3 PHASE 2.54T FRAME BELTS BX72Q354 DAYCO X 2 FILTER 24X24X2 PLEAT X 8

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
40083	AHU, 11A	AIR HANDLER UNIT	FC11.1028	TEMPTROL	76218	1	BALDO MOTOR 15 HP 1750 RPM 460 VOLT 25.0 AMP 3 PHASE 2.54T FRAME BELTS BX72Q354 DAYCO X 2 FILTER 24X24X2 PLEAT X 8
40084	AHU, 11B	AIR HANDLER UNIT	FC11.1058	TEMPTROL	76216	1	BALDO MOTOR 15 HP 1750 RPM 460 VOLT 25.0 AMP 3 PHASE 2.54T FRAME BELTS BX72Q354 DAYCO X 2 FILTER 24X24X2 PLEAT X 9
40085	AHU, 12A	AIR HANDLER UNIT	FC12.1028	TEMPTROL	76214	1	BALDO MOTOR 15 HP 1750 RPM 460 VOLT 25.0 AMP 3 PHASE 2.54T FRAME BELTS BX72Q354 DAYCO X 2 FILTER 24X24X2 PLEAT X 10
40086	AHU, 12B	AIR HANDLER UNIT	FC12.1058	AURORA PUMP	76212	1	BALDO MOTOR 15 HP 1750 RPM 460 VOLT 25.0 AMP 3 PHASE 2.54T FRAME BELTS BX72Q354 DAYCO X 2 FILTER 24X24X2 PLEAT X 11
40087	AHU, 13A	AIR HANDLER UNIT	FC13.1028	TEMPTROL	76210	1	BALDO MOTOR 15 HP 1750 RPM 460 VOLT 25.0 AMP 3 PHASE 2.54T FRAME BELTS BX72Q354 DAYCO X 2 FILTER 24X24X2 PLEAT X 12
40088	AHU, 13B	AIR HANDLER UNIT	FC13.1058	TEMPTROL	76208	1	BALDO MOTOR 15 HP 1750 RPM 460 VOLT 25.0 AMP 3 PHASE 2.54T FRAME BELTS BX72Q354 DAYCO X 2 FILTER 24X24X2 PLEAT X 13
40089	AHU, OA-2	AIR HANDLER UNIT	FC14.1028	TEMPTROL	76235	1	BALDO MOTOR 15 HP 1750 RPM 460 VOLT 25.0 AMP 3 PHASE 2.54T FRAME BELTS BX72Q354 DAYCO X 2 FILTER 24X24X2 PLEAT X 14

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
40090	AHU, OA-1	AIR HANDLER UNIT	FC14.1058	TEMPROL	76234	1	BALDOR MOTOR 20HP 1750 RPM 460 VOLT, 23 AMP 3PH 256T FRAME BELT BX87-2-Q37 DAYCO X 3 FILTER 24X 24X2 PLEAT 12
40092	FAN-EXH	ELECTRICAL ROOM EXHAUST FAN	FC3.1022			1	MOTOR: UNIVERSAL ELECTRIC MOTOR 1/8 HP 1050 RPM 60 AMPS PHASE 1 115 VOLTS
40093	FAN-EXH, #3	ELECTRICAL ROOM EXHAUST FAN	FC4.1022			1	MOTOR: UNIVERSAL ELECTRIC MOTOR 1/8 HP 1050 RPM 60 AMPS PHASE 1 115 VOLTS
40094	FAN-EXH	ELECTRICAL ROOM EXHAUST FAN	FC5.1022			1	MOTOR: UNIVERSAL ELECTRIC MOTOR 1/8 HP 1050 RPM 60 AMPS PHASE 1 115 VOLTS
40095	FAN-EXH	ELECTRICAL ROOM EXHAUST FAN	FC6.1022			1	MOTOR: UNIVERSAL ELECTRIC MOTOR 1/8 HP 1050 RPM 60 AMPS PHASE 1 115 VOLTS
40096	FAN-EXH	ELECTRICAL ROOM EXHAUST FAN	FC7.1022			1	MOTOR: UNIVERSAL ELECTRIC MOTOR 1/8 HP 1050 RPM 60 AMPS PHASE 1 115 VOLTS
40097	FAN-EXH	ELECTRICAL ROOM EXHAUST FAN	FC8.1022			1	MOTOR: UNIVERSAL ELECTRIC MOTOR 1/8 HP 1050 RPM 60 AMPS PHASE 1 115 VOLTS
40098	FAN-EXH	ELECTRICAL ROOM EXHAUST FAN	FC9.1022			1	MOTOR: UNIVERSAL ELECTRIC MOTOR 1/8 HP 1050 RPM 60 AMPS PHASE 1 115 VOLTS
40099	FAN-EXH	ELECTRICAL ROOM EXHAUST FAN	FC10.1022			1	MOTOR: UNIVERSAL ELECTRIC MOTOR 1/8 HP 1050 RPM 60 AMPS PHASE 1 115 VOLTS
40100	FAN-EXH	ELECTRICAL ROOM EXHAUST FAN	FC11.1022			1	MOTOR: UNIVERSAL ELECTRIC MOTOR 1/8 HP 1050 RPM 60 AMPS PHASE 1 115 VOLTS

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
40101	FAN-EXH	ELECTRICAL ROOM EXHAUST FAN	FC12.1022			1	MOTOR: UNIVERSAL ELECTRIC MOTOR 1/8 HP 1050 RPM 60 AMPS PHASE 1 115 VOLTS
40102	FAN-EXH	ELECTRICAL ROOM EXHAUST FAN	FC13.1022			1	MOTOR: UNIVERSAL ELECTRIC MOTOR 1/8 HP 1050 RPM 60 AMPS PHASE 1 115 VOLTS
40103	FAN-EXH	GENERATOR ROOM EXHAUST FAN	FC1.1032	MAGNETEK	5/L 40880A	1	MOTOR: UNIVERSAL ELECTRIC MOTOR .275 HP 850/1750 RPM 9.3 AMPS 60 HZ PHASE SINGLE 115 VOLTS
40105	FAN-EXH, F-VE-2	SERVER ROOM EXHAUST FAN	FC3.1024			1	MOTOR: UNIVERSAL ELECTRIC MOTOR 1/8 HP 1050 RPM 60 AMPS PHASE 1 115 VOLTS
40106	FAN-EXH, F-VE-3	SERVER ROOM EXHAUST FAN	FC4.1024	MAGNETEK	20L34036A	1	MOTOR: UNIVERSAL ELECTRIC MOTOR 1/8 HP 1050 RPM 60 AMPS PHASE 1 115 VOLTS
40107	FAN-EXH, F-VE-4	SERVER ROOM EXHAUST FAN	FC5.1022	MAGNETEK	30L34036A	1	CAT#12-12248131-114, 480/277VOLT, 225MAX AMP, 3PHASE, BREAKERS IN PANEL: MODEL#- EDB14020, 20AMPS, 277VOLTS, MODEL#EDB34050, 50AMPS, 480/277VOLTS, 18K A
40107	FAN-EXH, F-VE-4	SERVER ROOM EXHAUST FAN	FC5.1024	MAGNETEK	30L34036A	1	MOTOR: UNIVERSAL ELECTRIC MOTOR 1/8 HP 1050 RPM 60 AMPS PHASE 1 115 VOLTS
40108	FAN-EXH, F-VE-5	SERVER ROOM EXHAUST FAN	FC6.1024			1	MOTOR: UNIVERSAL ELECTRIC MOTOR 1/8 HP 1050 RPM 60 AMPS PHASE 1 115 VOLTS
40110	FAN-EXH, F-VE-7	SERVER ROOM EXHAUST FAN	FC8.1024	MAGNETEK	20L34036A	1	MOTOR: UNIVERSAL ELECTRIC MOTOR 1/8 HP 1050 RPM 60 AMPS PHASE 1 115 VOLTS

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
40112	FAN-EXH, F-VE-9	SERVER ROOM EXHAUST FAN	FC10.1024	MAGNETEK	20L 34036A	1	MOTOR: UNIVERSAL ELECTRIC MOTOR 1/8 HP 1050 RPM 60 AMPS PHASE 1 115 VOLTS
40113	FAN-EXH, F-VE-10	SERVER ROOM EXHAUST FAN	FC11.1024	MAGNETEK	20L3436A	1	MOTOR: UNIVERSAL ELECTRIC MOTOR 1/8 HP 1050 RPM 60 AMPS PHASE 1 115 VOLTS
40114	FAN-EXH, F-VE-11	SERVER ROOM EXHAUST FAN	FC12.1024	MAGNETEK	20L34036A	1	MOTOR: UNIVERSAL ELECTRIC MOTOR 1/8 HP 1050 RPM 60 AMPS PHASE 1 115 VOLTS
40115	FAN-EXH, F-VE-12	SERVER ROOM EXHAUST FAN	FC13.1024	MAGNETEK	30L 34036A	1	MOTOR: UNIVERSAL ELECTRIC MOTOR 1/8 HP 1050 RPM 60 AMPS PHASE 1 115 VOLTS
40116	FCU-16	FAN COIL UNIT	FC1.1032	INTERNAT ENVIRONMENTA L	993983001213	1	
40117	FCU-17	FAN COIL UNIT	FC1.1032	INTERNAT ENVIRONMENTA L	993983001213	1	SERIES E-2, CAT#NQOD442L22SCUNL, MAX AMPS: 225, PHASE 3, WIRE 4, 208Y/120M 240/120 DELTA 35 BREAKER SWITCHES @ 20AMPS AND 10KA
40118	FCU-18	FAN COIL UNIT	FC1.1028	INTERNAT ENVIRONMENTA L	993983001213	1	
40119	FCU-19	FAN COIL UNIT	FC1.1014	INTERNAT ENVIRONMENTA L	993983001213	1	
40120	FCU-1	FAN COIL UNIT	FC2.1028	INTERNAT ENVIRONMENTA L	99-277220	1	MOTOR GE MOTORS 60985 CPN#70021593 1/8 HP 950 RPM FILTERS 14 X 20 X 1 115VOLTS 2.70AMPS 60PHASE
40121	FCU-2	FAN COIL UNIT	FC3.1028	INTERNAT ENVIRONMENTA L	99-277220	1	MOTOR GE MOTORS 60985 CPN#70021593 1/8 HP 950 RPM FILTERS 14 X 20 X 1 115VOLTS 2.70AMPS 60PHASE

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
40122	FCU-3	FAN COIL UNIT	FC4.1028	INTERNAT ENVIRONMENTA L	99-277220	1	MOTOR GE MOTORS 60985 CPN#70021593 1/8 HP 950 RPM FILTERS 14 X 20 X 1 115VOLTS 2.70AMPS 60PHASE
40123	FCU-4	FAN COIL UNIT	FC5.1028	INTERNAT ENVIRONMENTA L	99-27220	1	MOTOR GE MOTORS 60985 CPN#70021593 1/8 HP 950 RPM FILTERS 14 X 20 X 1 115VOLTS 2.70AMPS 60PHASE
40124	FCU-5	FAN COIL UNIT	FC6.1028	INTERNAT ENVIRONMENTA L	99-277220	1	
40125	FCU-6	FAN COIL UNIT	FC8.1028	INTERNAT ENVIRONMENTA L	99-277220	1	
40126	FCU-7	FAN COIL UNIT	FC8.1028	INTERNAT ENVIRONMENTA L	99-277220	1	
40127	FCU-8	FAN COIL UNIT	FC9.1028	INTERNAT ENVIRONMENTA L	99-277220	1	
40128	FCU-9	FAN COIL UNIT	FC10.1028	INTERNAT ENVIRONMENTA L	99-277220	1	
40129	FCU-10	FAN COIL UNIT	FC11.1028	INTERNAT ENVIRONMENTA L	99-277220	1	
40130	FCU-11	FAN COIL UNIT	FC12.1028	INTERNAT ENVIRONMENTA L	99-277220	1	
40131	FCU-12	FAN COIL UNIT	FC13.1028	INTERNAT ENVIRONMENTA L	99-277220	1	
40132	FCU-15A	FAN COIL UNIT	FC14.1028	INTERNAT ENVIRONMENTA L	99-277220	1	MOTOR GE MOTORS 60985 CPN#70021593 1/8 HP 950 RPM FILTERS 14 X 20 X 1 115VOLTS 2.70AMPS 60PHASE

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
40133	FCU-14	FAN COIL UNIT	FC14.1060	INTERNAT ENVIRONMENTAL	99-227220	1	2XGE MOTOR 1/4 HP 1050 RPM 277 VOLT 1.05 AM SINGLE PHASE 6109 #70021548 2XFILTER 14X24X1
40134	FCU-15B	FAN COIL UNIT	FC14.1058	INTERNAT ENVIRONMENTAL	99-277220	1	
40135	PUMP-CHW, #1	CHILLED WATER PUMP #1	FC1.1032	MARATHON ELECTRIC	F899	1	BALDOR MOTOR: 10HP 1760 RPM, 230/460 VOLT, 25.8/12.9 AMP 3 PHASE 215T FRAME
40136	PUMP-CHW, #2	CHILLED WATER PUMP #2	FC1.1032	BALDOR	F899	1	BALDOR MOTOR 10 HPM, 1760 RPM 230/460 VOLT 25.8/12.9 AMP 3 PHASE 215T FRAME
40137	PUMP-CHW, #3	CHILLED WATER PUMP #3	FC1.1032	BALDOR	09904	1	BALDOR MOTOR 10 HPM, 1770 RPM 230/460 VOLT 70/35 AMP 3 PHASE 286T FRAME
40138	PUMP-CHW, #4	CHILLED WATER PUMP #4	FC1.1032	BALDOR	09904	1	BALDOR MOTOR 10 HPM, 1770 RPM 230/460 VOLT 70/35 AMP 3 PHASE 286T FRAME
40139	PUMP-CHW, #5	CHILLED WATER PUMP #5	FC1.1032	BALDOR	09904	1	
40140	PUMP-CHW, #6	CHILLED WATER PUMP #6	FC1.1032	PEERLESS	391842-732	1	BALDOR MOTOR 2 HPM, 1735 RPM 230/460 VOLT 6.6/3.3 AMP 3 PHASE 14S JM FRAME
40141	PUMP-HTG-HOT- WTR, #1	HEATING HOT WATER PUMP #1	FC1.1032	PEERLESS	CAT#EM33137	1	BALDOR MOTOR 10 HPM, 1760 RPM 230/460 VOLT 25.8/12.9 AMP 3 PHASE 215T FRAME
40142	PUMP-HTG-HOT- WTR, #2 HWP-2	HEATING HOT WATER PUMP #2	FC1.1032	PEERLESS	CAT#:EM33137	1	BALDOR MOTORS -182TC FRAME, 3 HP, 480VOLTS, 8.4AMPS, 3450RPM, 3PHASE
40143	PUMP-SUMP	TECO PIT SUMP PUMP	FC1.1032	GRUNDFOS	PS-99-45-228A	1	
40144	PUMP-SUMP	ELEVATOR PIT SUMP PUMP	FC1.1000	GRUNDFOS	PS-99452268	1	115VOLT, 0.5AMP, SIGNAL IN, SIGNAL OUT, TEMP. 50DEGREES, PART #549-504

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
40153	EXCH-HT-STM, #1	STEAM HEAT EXCHANGER #1	FC1.1032		99260	1	
40154	EXCH-HT-STM, #2 HEX-2	STEAM HEAT EXCHANGER #2	FC1.1032		99260	1	
40155	FPTU	FAN POWERED TERMINAL UNITS	FC1.3002	NAILOR	106492-73	1	MOTOR 1/2 HP & 1/4 HP @3.9 HP FRAME 1.8 AMPS BELTS 3 PHASE FILTERS 16X16X1 1 EA 277 VOLTS
40169	TANK-EXP-STM, S-E-T-I	STEAM EXPANSION TANK	FC1.1032	WENDLAND MFG CORP.	32695	1	
40170	CHW-TANK-EXP	CHILLED WATER EXPANSION TANK	FC14.1028	WHEATLEY	N/A	1	
40171	TANK-EXP-HWTR, ET-1	HOT WATER EXPANSION TANK	FC14.1028	WHEATLEY		1	
40177	CHW-EXCH-HEAT, #2	CHILLED WATER HEAT EXCHANGER #2	FC1.1032			1	
40178	CHW-EXCH-HEAT, #1	CHILLED WATER HEAT EXCHANGER #1	FC1.1032			1	
40186	VALVES	HOT AND COLD WATER, STEAM, CONDENSED, CHILLED WATER AND HEATING HOT WATER				1	
40187	PUMP-SUMP	WATER SUMP PUMP	FC1.1000		AKA01892526	1	115VOLT, 9.0AMP, SINGLE PHASE
40240	VFD1 - AHU 1B	VARIABLE FREQUENCY DRIVE FOR AHU-1B	FC1.1058	ABB	2993900138	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/63
40241	VFD, 28-OS	VARIABLE FREQUENCY DRIVE #28 FOR AHU-2	FC14.1058	ABB	2020700525	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/64
40242	VFD, 23	VARIABLE FREQUENCY DRIVE #23 FOR AHU-12B	FC12.1058	ABB	2993900173	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/65
40243	VFD, 24	VARIABLE FREQUENCY DRIVE #24 FOR AHU-12A	FC12.1028	ABB	2993700017	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/66
40244	VFD, 25	VARIABLE FREQUENCY DRIVE #25 FOR AHU-13B	FC13.1058	ABB	2993900118	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/67

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
40245	VFD, 9	VARIABLE FREQUENCY DRIVE #9 FOR AHU-5B	FC5.1058	ABB	299400021	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/68
40246	VFD, 10	VARIABLE FREQUENCY DRIVE #10 FOR AHU-5A	FC5.1028	ABB	2994000209	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/69
40247	VFD, 7	VARIABLE FREQUENCY DRIVE #7 FOR AHU-4B	FC4.1058	ABB	2994000209	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/70
40248	VFD, 5	VARIABLE FREQUENCY DRIVE #5 FOR AHU-3B	FC3.1058	ABB	2994100373	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/71
40249	VFD, 6	VARIABLE FREQUENCY DRIVE #6 FOR AHU-3A	FC3.1028	ABB	2994000213	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/72
40250	VFD, 3	VARIABLE FREQUENCY DRIVE #3 FOR AHU-2B	FC2.1058	ABB	2993900117	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/73
40251	VFD, F-SP-1	VARIABLE FREQUENCY DRIVE, F-SP-1	FC2.1058	ABB	2993400114	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/74
40252	VFD, #4	VARIABLE FREQUENCY DRIVE, # 4 FOR AHU-2A	FC2.1028	ABB	2994100247	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/75
40253	VFD, #29-F-SP-3	VARIABLE FREQUENCY DRIVE, # 29-F-SP-3	FC14.1028	ABB	2993800085	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/76
40254	VFD, #27-0S	VARIABLE FREQUENCY DRIVE #27 FOR OSAHU-1	FC14.1028	ABB	2993400109	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/77

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
40255	VFD, #30-F-SP-4	VARIABLE FREQUENCY DRIVE #30-F-SP-4	FC14.1028	ABB	299400113	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/78
40256	VFD, #21	VARIABLE FREQUENCY DRIVE #21 FOR AHU-11B	FC11.1058	ABB	2002700204	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/79
40257	VFD, #11	VARIABLE FREQUENCY DRIVE #11 FOR AHU-11A	FC11.1058	ABB	2994000218	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/80
40258	VFD, #19	VARIABLE FREQUENCY DRIVE #19 FOR AHU-10B	FC10.1058	ABB	2993700018	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/81
40259	VFD, #10	VARIABLE FREQUENCY DRIVE #10 FOR AHU-10A	FC10.1028	ABB	2993900125	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/82
40260	VFD, #17	VARIABLE FREQUENCY DRIVE #17 FOR AHU-9B	FC9.1058	ABB	2012800042	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/83
40261	VFD, #17	VARIABLE FREQUENCY DRIVE #18 FOR AHU-9A	FC9.1058	ABB	2993900088	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/84
40262	VFD, #15	VARIABLE FREQUENCY DRIVE #15 FOR AHU-8B	FC8.1058	ABB	2993600248	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/85
40263	VFD, #16	VARIABLE FREQUENCY DRIVE #16 FOR AHU-8A	FC8.1028	ABB	2993900090	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/86
40264	VFD, #13	VARIABLE FREQUENCY DRIVE #13 FOR AHU-7B	FC7.1058	ABB	2993900124	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/87

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
40265	VFD, #14	VARIABLE FREQUENCY DRIVE #14 FOR AHU-7A	FC7.1028	ABB	2993800113	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/88
40266	VFD, #11	VARIABLE FREQUENCY DRIVE #11 FOR AHU-6B	FC6.1028	ABB	2994000208	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/89
40267	VFD, #2	VARIABLE FREQUENCY DRIVE #2 FOR AHU-6A	FC2.1058	ABB	2994000210	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/90
40268	VFD, #26	VARIABLE FREQUENCY DRIVE #26 FOR AHU-13A	FC13.1028	ABB	2993600247	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/91
40269	VFD, #8	VARIABLE FREQUENCY DRIVE #8 FOR AHU-4A	FC4.1028	ABB	2993600246	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/92
40270	VFD, #12	VARIABLE FREQUENCY DRIVE #12 FOR AHU-6A	FC6.1028	ABB	2994000210	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/93
40317	VFD, 34	VARIABLE FREQUENCY DRIVE #34 FOR CHWP2	FC1.1032	ABB	2993400042	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/94
40318	VFD, 1	VARIABLE FREQUENCY DRIVE FOR AHU-1A	FC1.1028	ABB	2993900138	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/95
40319	VFD, 38	VARIABLE FREQUENCY DRIVE FOR AHU-1A	FC1.1032	ABB	2993900138	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/96
40320	VFD, 37	VARIABLE FREQUENCY DRIVE FOR HWP-1	FC1.1032	ABB	2993900138	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/97

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
40321	VFD, 36	VARIABLE FREQUENCY DRIVE FOR HWP-4	FC1.1032	ABB	2993900138	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/98
40322	VFD, 32	VARIABLE FREQUENCY DRIVE	FC1.1032	ABB	2993900138	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/99
40323	VFD, 33	VARIABLE FREQUENCY DRIVE	FC1.1032	ABB	2993900138	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/100
40324	VFD, 35	VARIABLE FREQUENCY DRIVE #35 FOR CHWP-3	FC1.1032	ABB	2993300294	1	REFER TO MANUAL: ACH4DO 3 PHASE, 380/480v, 29/30AMPS, H2 - 48/101
	FPTU	FAN POWERED TERMINAL UNITS	Faculty Center			644	
<b>Subtotal</b>						<b>783</b>	
<b>Bellaire Treatment Center</b>							
42000	FAN-EXH	Exhaust Fan	BTC. roof	MARATHON ELECTRIC		1	CAT#B303, FRAME 482M 1 PHASE, TYPE 55, 1725RPM, 1/4HP, 115VOLTS, FLA-5.0 MODEL : GB-120-4, SERIAL#99J.10741 BELT: ONE ONLY, SZIE:3L-200
42002	COMP-AIR	Air Compressor	BTC.electrical rm	SPEEDAIRE	2216183708	1	120VOLT, 15AMP, 60HZ, 1PHASE, MAX PSI: 175, 20GAL
42003	AC, #3	Air Conditioner Unit	BTC. roof	CARRIER	0993G27522	1	COMPRESSOR - 460VOLTS, 3PHASE, 60HZ, RLA10.4-LRA.72-R22, 9.7LBS, FAN MOTOR-460VOLTS, 1PHASE, 60HZ, FLA1.0 1 SAFETY SWITCH- GENERAL ELECTRIC, 30AMP,600VOLTS, 3PHASE #NP266212-D, NONE FUSE

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
42004	AC, #2	Air Conditioner Unit	BTC. roof	CARRIER	0993G27566	1	COMPRESSOR - 460VOLTS, 3PHASE, 60HZ, RLA10.4-LRA.72-R22, 9.7LBS, FAN MOTOR-460VOLTS, 1PHASE, 60HZ, FLA1.0 1 SAFETY SWITCH- GENERAL ELECTRIC, 30AMP,600VOLTS, 3PHASE #NP266212-D, NONE FUSE
42005	AC, #1	Air Conditioner Unit	BTC. Roof	CARRIER	0993G27564	1	COMPRESSOR - 460VOLTS, 3PHASE, 60HZ, RLA10.4-LRA.72-R22, 9.7LBS, FAN MOTOR-460VOLTS, 1PHASE, 60HZ, FLA1.0 1 SAFETY SWITCH- GENERAL ELECTRIC, 30AMP,600VOLTS, 3PHASE #NP266212-D, NONE FUSE
42005	AC, #1	Air Conditioner Unit	BTC. roof	CARRIER	0993G27564	1	
42006	AC, #4	Air Conditioner Unit	BTC. roof	CARRIER	0993G27565	1	COMPRESSOR - 460VOLTS, 3PHASE, 60HZ, RLA10.4-LRA.72-R22, 9.7LBS, FAN MOTOR-460VOLTS, 1PHASE, 60HZ, FLA1.0 1 SAFETY SWITCH- GENERAL ELECTRIC, 30AMP,600VOLTS, 3PHASE #NP266212-D, NONE FUSE
42019	DRYR-COMP-AIR	Refrigerated Air Dryer	BTC.outside elect rm	SPEEDAIRE	2452947-009	1	HP-1/6, SCFM-5/10, 115 VOLTS, 1 PHASE, 60HZ,
42038	CHR	Chiller	BTC.Roof	ARCTI CHILL	A013019603	1	10KVA, 60HZ, 1PHASE, TYPE:QMS, PRI-432/456/480VOLTS, SEC-120/240VOLTS NP#475A738AAP236-R3-197LB
<b>Subtotal</b>						<b>9</b>	

Fannin Office Building

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
43001	AC, RTU #2A	AIR CONDITIONER UNIT - ROOF	FOB.Roof	CARRIER	2901G41399	1	1 COMP, 208/230VOLTS, SINGLE PHASE, 60HZ, 20.4RLA, 104LRA, 5.2LBS, R-22, HI-300PSI, LOF-150PSI/208/230, SINGLE PHASE, 60HZ, 2 FAN MOTOR, 208/230VOLTS, SINGLE PHASE, 60HZ, INDOOR 1.4FLA, OUTDOOR 4.0FLA DISCONNECT - SIEMENS, 30AMP 240VOLT
43008	FAN-EXH	EXHAUST FAN	FOB.Roof	LOREN COOK CO	EF-1-MDA	1	1669RPMS - 1-4HP - 1PHASE, 60HZ, 115VOLTS
43009	FAN-EXH	EXHAUST FAN	FOB.Roof	LOREN COOK CO	EF-1-MDA-1626	1	1550RPMS, 1/8HP, 1 PHASE-60HZ, 115VOLTS
43036	AC-PKG-UNIT, RTU-1B	A/C PACKAGE UNIT	FOB ROOF	CARRIER		1	BELT A53 1 FILTER PLEATED 20 X 20 X 2 4 EA 460 VOLTS 3 PHASE 60 HZ
43037	AC-PKG-UNIT, RTU-2B	A/C PACKAGE UNIT	FOB ROOF	CARRIER		1	BELT A36 1 FILTER PLEATED 16 X 25 X 2 2 EA 208/230 VOLTS 1 PHASE 60 HZ
43038	AC-PKG-UNIT, RTU-1A	A/C PACKAGE UNIT	FOB ROOF	CARRIER		1	BELT A53 FILTER 20 X 20 X 2 460 VOLTS 3 PHASE 30 AMPS 4000 CFM 10 HP 60 HZ BUT 120000
<b>Subtotal</b>						<b>6</b>	
<b>Pawnee Street Warehouse</b>							
40193	PUMP-HOT-WTR-CIR	BOILER HOT WATER CIRCULATING PUMP	WPS1.1000			1	
40195	AHU, #1	AIR HANDLER #1	WPS1.1000			1	
40196	PUMP-CHW, #1	CHILLED WATER PUMP #1	WPS1.1000			1	
40197	PUMP-CHW, #2	CHILLED WATER PUMP #2	WPS1.1000			1	
40198	PUMP-HTG-HOT-WTR, #1	HEATING HOT WATER PUMP	WPS1.1000			1	
53003	AHU, #2	AHU	WPS2	CARRIER		1	BELTS 4 BP-105 FILTERS 4 22X24 PADS 10 20 X 24 PADS ACTUATORS HONEYWELL 230/460 VOLTS 24.7/12.3 AMPS 10 HP 60 HZ 1765 RPM FRAME 215T

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
53004	PUMP-CHW, CHP-2	CHILL WATER PUMP	WPS2.Boiler Room	BALDOR	FO204083053	1	MOTOR: 1.5HP, 1740RPM, 230/460VAC, 4.2/2.1AMPS, 3PH, 60HZPUMP: 1510BF, CL8167-02 AZO, 175JAXWP, 80GPM, 35FT, 0.5HP, 1.5AC
53005	PUMP-CHW, CHP-1	CHILL WATER PUMP	WPS2	BALDOR	FO204083038	1	MOTOR: 1/12HP, 230/460VAC, 4.2,2.1AMPS, 1740RPM, 145T FRAME, 60HZ, 3PH, PUMP: CF3544-02K10, 1.5AC, 175MAX WP, GPM80, 35FT, 0.5HP, 180RPM
53006	FAN-EXH, EF-2	EXHAUST FAN	WPS.Roof	EVAIR	1807B	1	1/6HP, 1PH, 60HZ, 115VAC
53007	FAN-EXH, WHSE	EXHAUST FAN	WPS.Warhse Roof	POWERMASTER	0111300313	1	1PH, 60HZ, 2/4HP, 230/460VOLT, 5.6/2.8, RPM-1720, FRAM: 145T/BEARING: 62062B/62052LB, BELT A74 (2). QTY: 4 FANS ON ROOF
53010	PUMP-HOT-WTR, #2	Hot Water Pump #2	WPS2.Boiler Rm	EMERSON		1	MAKE OF HEATER: 510 SERIES, GALLONS: 10, LOWER ELEMENT: 1650WATTS, 120VOLTS, MAX HYDROSTAT WORKING PRESSURE: 150PSI
53014	PUMP-HOT-WTR, #1	Hot Water Pump	WPS2.Boiler Rm	BALDOR		1	FOR SERVICE CALL: 802-496-4436, FIDDLERS GREEN, WAITSFIELD, VT 05673, MADE IN ENGLAND, 220VOLTS, 30AMPS
53015	FAN-EXH, EF-1	Exhaust Fan	WPS.Roof	LOREN COOK CO		1	3HP, RPM-1725, 230/460VOLTS, 9.0-4.5AMPS, 3PHASE
53017	AC, WINDOW	Air Conditioning Unit window unit	WPS.Chem Stor Rm	FRIEDRICH	LCGR15971	1	CAT#EM3116T, 1HP, 230/460VOLTS, AMPS 2,8,4 - RPM 1740, FRAME 143, 60HZ, 3PHASE, BEARING 0E6203, ODE BREARING 6203

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
53018	AC, WINDOW	A/C unit window	WPS.Chem Stor Bldg	FRIEDRICH	LBGR07904	1	1PH, 60HZ, 115VAC, 1198-1/6, 1725/0000, EF-1 MDACC FACILITIES - SIG
53019	AC, WINDOW-SML BLDG	A/C unit window	WPS.Chem Stor Bldg	FRIEDRICH	LCAR10533	1	208-230 VOLTS BTU-18800 - 19000 8.5 AMPS - FAN MOTOR 1/4 HP
53021	FAN-EXH	Exhaust Fan	WPS.Chem Stor Rm		5KH35LNB164J X	1	115 VOLTS - SINGLE PHASE 1/4 HP - 1723 RPM 3.3 AMPS CAT W456
53022	FAN-EXH	Exhaust Fan	WPS.Chem Stor Bldg		5KH35LMB164J X	1	115 VOLTS - SINGLE PHASE 1/4 HP - 1723 RPM 3.3 AMPS CAT
53058	TANK-EXP, BLR	Expansion Tank	WPS2.Boiler Room	JOHNWOOD COMPANY	124240	1	MAWP 150 AT 240 DEGREES FARENHEIT, MDMT 32DEGREES FARENHEIT AT 150PSI
53059	CHR, #1	AIR COOLED CHILLER	WPS.Roof	CARRIER	1798F39289	1	FACTORY CHARGED R-22 REFRIGERANT, COMPRESSORS: 1-460VAC, 3PH, 60HZ, 34.6RLA, 173RLA, 40LBS CHARGE, 1-460VAC, 3PH, 60HZ, 43.6RLA, 22.3LRA, 46LBS CHARGE, FAN MOTOR: 2-460VAC, 3PH, 60HZ, 3.3FLA, 1HP, .746KW OUT, 2-460VAC, 3PH, 60HZ, 2.8FLA, 1HP, .746KW OUT, MIN CIR AMPS 101.3, MAX CIR AMPS 125, CONTROL VOLTAGE - 115VAC, 1PH, 60HZ, 30AMP
53065	TANK-EXP-BLR	Expansion Tank For Boiler	WPS2.Boiler Room	STOYSTOWN TANK & STEEL	124287	1	GALLONS: 75, OPERATES @ 12 TO 20PSI, MAXIMUM LIMIT OF 40PSI, MAWP 125PSI @ 240 DEGREES FARENHEIT, 32DEGREES @ 125PSI

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
53074	BLR, LOW PRESS B-1	Low Press Boiler	WPS2.Boiler Room	LOCHINVAR	D028650	1	GAS FIRED HOT WATER BOILER, MAX WP-160PSI, INPUT RATING, 1,000,000 OUTPUT BTU/HR 880,000 CRN#H1168.12547890TY
<b>Subtotal</b>						<b>22</b>	
<b>Fannin South Professional Building</b>							
44000	UNIT-CD-AIR-#2	Air Condensor	FSP.GARAGE LOWER LVL	CARRIER	2102E10974	1	208/230VOLTS, COMP, 1 PHASE, 60HZ, 14.1RLA, 73.0LRA, FAN MOTOR, 208/230VOLTS, 1PHSE, 60HZ, 1/10HP, FLA: 8, UNIT HAS A SAFETY SWITCH-SIEMENS, 30AMP, 1 PHASE, 208VOLTS
44001	UNIT-CD-AIR-#5	Air Condensor	FSP.GARAGE LOWER LVL	CARRIER	2102E10711	1	230VOLTS, 208VOLTS, COMP 230VOLTS, 60HZ, 9.0FLA, 48LRA, 1 PHASE, MOTOR - 1/8PHASE, FLA 8, UNIT HAS A SIEMENS SAFETY SWITCH, 30AMP, 240VOLT
44002	AC, #3	Air Conditioning Unit	FSP1.145	CARRIER	1902E15766	1	208/230VOLTS, COMP 1PHASE, 60HZ, 11.6RLS, 60.0LRA, FAN MOTOR: 208/230VOLTS, 1/6HP, FLA 1.0, 1 PHASE, 60HZ, UNIT HAS A SIEMENS SAFETY SWITCH, 30AMPS, 208VOLTS
44003	AC, #4	Air Conditioning Unit	FSP.GARAGE LOWER LVL	CARRIER	1902E21060	1	208/230VOLTS, COMP 1PHASE, 60HZ, 11.6RLS, 60.0LRA, FAN MOTOR: 208/230VOLTS, 1/6HP, FLA 1.0, 1 PHASE, 60HZ, UNIT HAS A SIEMENS SAFETY SWITCH, 30AMPS, 208VOLTS
44003	AC, #4	Air Conditioning Unit	FSP.GARAGE.LW R LVL	CARRIER	1902E21060	1	

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
44004	AC, #1	Air Conditioning Unit	FSP.GARAGE	CARRIER	1902E15771	1	PISTON ID: 59, COMPRESSOR: 11.6RLA, 60LRA, R-22, 3.65LBS, 208/230VOLTS, SINGLE PHASE, 60HZ, FAN MOTOR: 208-230VOLTS, 1/6HP, 1.0FLA, MAX FUSE: 20AMPS, SAFETY SWITCH: SIEMENS, 30AMP, PHASE: ONE, VOLTS: 208, NON FUSE
44005	FAN-EXH, EF-1	Exhaust Fan #1	FSP	LOREN COOK CO		1	MOTOR, 115 V, 1/4 HP, 1725 RPM, 4.8 AMPS, 1 PH
44006	DSCNT-FCU, #1	Service Disconnect to Fan Coil Unit #1	FSP	SIEMENS		1	120VOLTS, 60HZ, FREQUENCY: 2450, 1.25KW, PHASE: SINGLE SERVICE DISONNECT, 30 MP, 240 VOLTS, 10 PHASE
44007	FCU, #1	Fan Coil Unit #1	FSP	CARRIER	2202A56525	1	EVAPORATOR MOTOR, MOTOR HP 1/5, MOTOR FLA 1.5, VOLTS 208/230 SINGLE PHASE, PHASE/HERTS - 1/60 115VOLTS, 1.4AMPS, 60HZ, R-134A, 2OUNCES, PHASE: ONE
44008	DSCNT-FCU, #2	Service Disconnect to Fan Coil #2	FSP	SIEMENS		1	SERVICE DISONNECT, 30 AMP, 240 VOLTS, 10 PHASE
44009	FCU, #2	Fan Coil Unit #2	FSP	CARRIER	2202A56282	1	EVAPORATOR MOTOR, MOTOR HP 1/4, MOTOR FLA 1.8 VOLTS, 208/230 10 PHASE, PHASE/HERTZ 1/60
44010	DSCNT-FCU, #3	Service Disconnect to Fan Coil #3	FSP	SIEMENS		1	SERVICE DISCONNECT, 60 AMP, 240 VOLTS, 10 PHASE
44011	FCU, #3	Fan Coil Unit #3	FSP	CARRIER	2202A62812	1	EVAPORATOR MOTOR - MOTOR HP 1/3, MOTOR FLA 2.4, VOLT 208/230, 10 PHASE, PHASE/HERTZ 1/60

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
44011	FCU, #3	Fan Coil Unit #3	FSP1.140A	CARRIER	2202A62812	1	
44012	DSCNT-FCU, # 4	Service Disconnect to Fan Coil #4	FSP	SIEMENS		1	SERVICE DISCONNECT, 30 AMP, 240 VOLTS, SINGLE PHASE
44013	FCU, #4	Fan Coil Unit #4	FSP	CARRIER	2202A56286	1	EVAPORATOR MOTOR: VOLTS - 208/230, HP-1/4, AMPS - 1.8, PH-1, REFRIGERANT - R22
44014	DSCNT-FCU, #5	Service Disconnect to Fan Coil #5	FSP	SIEMENS		1	SERVICE DISCONNECT - 30 AMP, 240 VOLTS, PH-1
44015	FCU, #5	Fan Coil Unit #5	FSP	CARRIER	2202A56285	1	EVAPORATOR MOTOR: VOLTS - 208/230, HP-1/4, AMPS - 1.8, PH-1, REFRIGERANT - R22
<b>Subtotal</b>						<b>18</b>	
<b>Data Center " Guhn Road"</b>							
57050	VFD-AHU, #1	VFD FOR AIR HANDLER UNIT	DCG1.1070	OMRON IDM		1	Spec:40151F, Lot No:1W0071000710021, U.L. File No:E131457, Equip:7J48B, Input: A.C., 3 phase 380-460, 50 hz, 40 amp, 380-460, 60 hz. Output:AC, 3 phase, 0-460V, 0-400hz, 34 amps 100:Amps Volts:600AC/250DC, Phase:3, No Fuses, Cat#:HU-363, Series:D3
57055	VFD-AHU, #2	VFD FOR AIR HANDLER UNIT	DCG1.1070	OMRON IDM		1	Spec: 40151F, Lot No:1W0071000710019, Mass:11kg, UL File No:E131457, Input: AC, 3 phase, 380-460V, 50 hz, 40 amp, 380-460v, 60 hz, output:AC, 3 phase, 8-460V, 0-400hz. 34 amp.

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
57056	VFD-AHU, #3	VFD FOR AIR HANDLER UNIT	DCG1.1070	OMRON IDM			1 spec:4015F, Equip:7J48B, Lot no:U-0006238-027, Mass:11kg, UL File:No:E131457, output:ac, 3 phase, 0-460v, 0-400hz, 34 amps, Input:ac, 3 phase, 380-460v, 50hz, 40 amps, 380-460v. 60hz.
57116	DMPR-ACT, FSD-6 (Zone 6)	Actuator Damper	DCG1.1021	INVENSYS	2-POS		1 Volts:12, HZ:60, Watts:30, Amps:.63, Amb Temp: 0 degree to 140 degree F.
57117	DMPR-ACT, FSD-5 (Zone 6)	Two directed couple Actuator	DCG1.1021	HONEYWELL	08526718315		1 Volts: 120, Cycles: 60CPS, Amps:.18, Temp:0degree to 130 degree F
57120	VFD-AHU, #4	VFD FOR AIR HANDLER UNIT	DCG	OMRON IDM			1 Spec:40151F, Lot No:1W0071000710020, mass:11kg., ULFile No:E131457, Input:AC, 3 phae, 380-460, 50 hz, 40 amp, 380-460, 60hz. Output: ac, 3 phase, 0-460v, 0-400hz, 34 amp
57902	CHR, #3	Chiller #3	DCG1.1000	YORK	RLJM6510AA		1 Type: Air Cooled - screw liquid, 230 tons, 30 hp, 3550 RPM, 460 volts, 163 amps, 3 phase, comp. 1 and 2-460 volt, 3 phase, delta LRA-893, WYELRA-250 part #364-49094-115, condenser mtoor-Magnetek, part #9-391968-62, 3 phase, 460 volt, 1.8 hp, 3.6 amp, 145T Frame, 850 RPM, 10 atv

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
57903	CHR, #2	Chiller #2	DCG1.1000	YORK	RLJM6520AA	1	Type: Air cooled-screw liquid, 230 tons, 30 hp, 3550 RPM, 460 volts, 163 amps 3 phase, comp 1 and 2-460 volt, 3 phase, delta LRA 893, WYE LRA 280, part #364-49094-115, Condenser Motor- Magnetek, Part #9-391968-62, 3 phase, 460 volt, 1.8 hp, 3.6 amp, 145T frame, 850 RPM, 10 atv
57904	CHR, #1	Chiller #1	DCG1.1000	YORK	RLJM6500AA	1	Type: Air cooled - screw, liquid, 230 tons, 30 hp, 3550 RPM, 460 volts, 163 amps, 3 phase comp 1 and 2 - 460 volts, 3 phase, delta LRA 893, WYELRA-280, Part#364-490094-115, condenser motor-magnetek, part #9-391968-62, 3 phase 460 volt, 1.8 hp, 3.6 amp, 145T frame, 850 RPM, 10 quty.
57905	AHU, #1	Air Handler Chiller	DCG.000	THERMAL CORP	01-9109-02	1	Baldor Motor Model#EM2531T, Bearing Front 6311-Rear 6309, beltsize B105, Qty 5-3, volts 230./460-3 phase-60/30 amps, 25 hp-RPMS 1770 frame, 284T, air filters 24x24x4, qty5-20 to air filters 24x24x2 qty 5-20
57906	AHU, #2 THERMAL	Air Handler Unit	DCG.000	THERMAL CORP	01-9109-01	1	Baldor Motor Model #EM253T 240/460 volts, 25 HP, 1770 rpm, 3 phase, 60/30 amps, 284T frame, bearings: frnt 6311, rear-6309, belt: B105-3 qty, filter: 24x24x2-20 atv. 24x24x4-20 atv

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
57907	AHU, #3	Air Handler Unit	DCG.000	THERMAL CORP	01-9109-03	1	Baldor Motor-Model EM253T, Volts 230/460-3 phase-60/30 amps, 25HP-RPMS 1770 frame 284T, Bearing front 6311 rear 6309, belt size b105 qty S-3, air filters 24x24x4 qtys 20, air filters 24x24x2 atvs 20
57908	AHU, #4 OS-N	Air Handler #4	DCG.000	THERMAL CORP	01-9109-04	1	Baldor Motor: 230/460 volt, phase 3, amps 60/30, HP25, RPMs:1770, model:#EM253T, frame: 284T, bearings front:6311, rear bearing 6309, belts:B-105, 3 ea., air filters:24x24x4, 20 ea., air filters:24x24x2, 20 ea.
57909	AHU, #5 OS-N	Air Handler Unit	DCG.000	THERMAL CORP	01-9109-05	1	Baldor motor: Model #EM253T, 25HP, 230/460 volt, 60/30 amp, 1770 RPM, 3 phase, 284T frame, bearings: front 6311, rear-6309, belt:B105-3 qty, Filter: 24x24x2 - 20 qty, 24x24x4 - 20 atv
57915	BLR, #1	Ajax Boiler	DCG1.000 OTSDE W	AJAX BOILER INC	58202	1	48 hp 120 volt 12 amp, 2ingle phase, high fire 140 degree F, operating 150 defree F, high limit 200 degree F, max input BTU-2,000,000/output BTU-1,600,000, min gas press - 7 in. wc/max gas-14 in. w.c. 125 psi, relief press, valve-75lb set, 1 in size, model-M no-740.
57916	PUMP-HOT-DWTR, #1	Hot Water Pump #1	DCG1.000 OTSDE W	TACO		1	Baldor Motor - Cat#EM4104T, 30 hp, 230./460 volt, 72/36 amp, 1780 RPM, 286T frame, bearings: DE-6311, ODE-6309. pump-200 GPM

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
57917	PUMP-CHW, #1	Chilled Water Pump #1	DCG1.000 OTSDE W	TACO		1	Baldor Motor - Cat #EM4104T, 30 hp, 230/460 volt, 72/36 amp, 1780 RPM, 286T Frame, Bearings: DE-6311, ODE=-6309, pump 500 GPM
57918	PUMP-CHW, #2	Chilled Water Pump#2	DCG1.000 OTSDE W	TACO		1	Baldor Motor-Cat#EM4104T, 30 hp, 230/460 volt, 72/36 amp, 1780 RPM, 286T frame, Bearings-DE-6311, ODE-6309, pump - 500 GPM
57919	PUMP-CHW, #3	Chilled Water Pump #3	DCG1.000 OTSDE W	TACO		1	Baldor Motor-Cat#EM4104T, 30 hp, 230/460 volt, 72/36 amp, 1780 RPM, 286T frame, Bearings-DE-6311, ODE-6309, pump - 500 GPM
57920	VALVE-ISO, #3	ISO Valve	DCG.000	ELECTRIC POWER	RBC02951	1	120 volt, 60 hz, 0.70 amp
57921	VALVE-ISO #2	ISO Valve #2	DCG.000	ELECTRIC POWER	RBC02951	1	120 volts, 60 hz, 0.70 amps
57922	VALVE-ISO #1	ISO VALVE #1	DCG.000	ELECTRIC POWER	RBC02951	1	120 volt, 60 hz, 0.70 amp
57923	COMP-AIR, #1	Air Compressor	DCG1.1070	INGERSOLL- RAND	TNJ160223	1	Tank: 30 hp/cv, max pres.-125 psi, pump-ac-0336, 20 gal, GE motor, 5450 RPM, 115/230 volt, 15/7.5 amp, single phase, 56 frame, part#Mo 3019-2, belt 380J6
57126	VFD-AHU, #5	VFD FOR AIR HANDLER UNIT	Guhn Rd.	OMRON IDM		1	
<b>Subtotal</b>						<b>24</b>	
<b>Grand Total</b>						<b>988</b>	

HVAC System Equipment List for All Properties Minus SCS

ASSET NO.	ASSET SHORT DESCRIPTION	ASSET LONG DESCRIPTION	LOCATION	MANUFACTURER	SERIAL NO.	QTY	SPECS
-----------	-------------------------	------------------------	----------	--------------	------------	-----	-------